



## Product Safety Notice

Certain black plastic Zytel® nylon valve disposable fire extinguishers.

### Not Affected:

- Professional Kidde and Badger Advantage models
- Fire Extinguishers Purchased Prior to August 2013 or After November 2014

## Recall Summary

**Name of Product:** Items affected are Kidde brand, black plastic Zytel® nylon valve disposable extinguishers both ABC and BC rated models manufactured between July 23, 2013 and October 15, 2014 and sold between August 2013 and November 2014. The affected fire extinguishers are white or red in color and are either ABC or BC-rated. The Kidde logo and serial number are located on the nameplate. The date code is an ink jet 10-digit number stamped on the side of the cylinder near the bottom. Digits 5-9 of this number convey the day and year of manufacture. Affected units will have the following five digits in a date code:

2013: XXXX20413X through XXXX36513X

2014: XXXX00114X through XXXX28814X

The models are as follows:

46-0066	FC5	KFH
46-0092	FH/ RESSP	M10G
AUTO FX11	FS10	M10GM
AUTO FX511	FS110	M110
BC5GD	FS5	M110G
E10	FULL HOME 110	M110GM
E10H	FX10	M5
E110	FX10BC	M5C
E5	FX10K	M5G

ELITE 10	FX210	M5GM
ELITE 10 HOME	FX210R	MARINER 10
FA10G	FX210W	MARINER 110
FA10T	FX340GW	MARINER 5
FA110	FX340SC	MARINER 5 G
FA110G	FX340SCGW	MG10GM
FA5	FX511	RESSP
FA5B	FX5II	XL 5MR
FC10	H110G	FA5G
FC110	H5G	

**Hazard:** Kidde has identified a quality issue with black plastic Zytel® nylon valve disposable fire extinguishers. In a small number of instances, Kidde found that a supplier built a component that is out-of-specification. When the lever is pressed and released multiple times, the extinguisher may fail to fully discharge as designed.

**Remedy:** Replace.

**DETERMINE IF YOU HAVE AN AFFECTED PRODUCT**

[See Full Recall Announcement](#)

[Frequently Asked Questions](#)

[Home](#) | [Privacy Policy](#) | [Terms of Use](#)  
Kidde is part of [UTC Building & Industrial Systems](#), a unit of [United Technologies Corp.](#)



Powered by Inmar